

Item	Quantity	Description	Unit Price [Euro]	Price [Euro]
		<p>KRAITEC® top is a protective layer / layer in the sense of DIN 18531, 18533, 18535 as well as the national (German) flat roof guidelines this is used to protect against mechanical damage on the flat roof.</p> <p>When tested according to EN 12691 (Resistance to Impact), KRAITEC® top mats 6 mm or greater in thickness withstand impact from heights \geq 2500 mm.</p> <p>When tested according to SIA 280 (Puncture Resistance), KRAITEC® top withstands impact from the following maximum drop heights: 800 mm for 6 mm mat thickness 1000 mm for 8 mm mat thickness 1300 mm for 10 mm mat thickness</p> <p>These structural protection mats fabricated from granulated rubber crumbs have a density of approx. 900 kg/m² and an E_{fl} fire resistance rating (normal fire resistance) according to EN 13501 Part 1. They are available in thicknesses from 6 mm to 20 mm.</p> <p>Installation to be carried out as specified in manufacturer's installation instructions.</p> <p>Manufacturer: KRAIBURG Relastec GmbH & Co. KG Fuchsbergerstr. 4, D-29410 Salzwedel / Germany Tel.: +49/8683-701-167 Fax: +49/8683-701-4177</p>		

This data sheet is not subject to change management! No liability accepted for errors or omissions.
The current valid version can be called up at www.kraiburg-relastec.com/kraitec

Page 1 von 2

Item	Quantity	Description	Unit Price [Euro]	Price [Euro]
1.	_____	m ² KRAITEC® top structural protection mats, length l = 2000 / 2300 mm, width w = 1000 / 1150 mm, thickness t = ___ mm. To be supplied, unloaded from transport lorry and brought to the point of installation.		
1.1.	_____	alternative: m ² KRAITEC® top roll-form structural protection mats, length l = _____ mm, width w = 1250 mm, thickness t = ___ mm. To be supplied, unloaded from transport lorry and brought to the point of installation.		
2.	_____	m ² installation of mats in loose masonry-style configuration, with min. 5 cm width overlap and min. 10 cm length overlap. (Installation to be carried out as specified in manufacturer's installation instructions.)		
3.	_____	alternative: m ² installation of mats on green roofs in loose masonry-style configuration, with min. 10 cm width overlap and min. 10 cm length overlap. (Installation to be carried out as specified in manufacturer's installation instructions.)		
4.	_____	alternative: m ² separating layer (required material and thickness to be specified/approved by roofing membrane manufacturer) to be supplied and installed. Materials: _____ Labour: _____		

DISCLAIMER:

With our information we desire to advise you to the best of our knowledge and belief based on our trials and experiences. However, KRAIBURG Relastec GmbH & Co. KG cannot accept a warranty for the processing result in the specific case, due to the variety of use possibilities, and the storage, processing, and construction site conditions for our KRAITEC® products that are beyond our control. The customer must execute his own tests. Our technical customer service organization is available to you.

This data sheet is not subject to change management! No liability accepted for errors or omissions.
The current valid version can be called up at www.kraiburg-relastec.com/kraitec